

GROUND LIGHTING EQUIPMENT

Description of function

CONTROL AND MONITORING OF AIRFIELD

• airfield ground lighting equipment are shown on the screen representing the airport layout


 control of airfield ground lighting equipment is made by trackball and push-buttons situated at

the bottom on the screen (touchscreen)

SOFTWARE

chapter:

2.3



CONTROL AND MONITORING CCR

➡Application

• backgrounds a status of each CCR

Description/Properties


CCR's name (light system) is in its head. The regulators background own status via values:


- ON/OFF
- Control mode remote/local
- Fault fault of regulation
- OVC over current
- OPC open circuit
- LF L1 lamp fault level 1
- LF L2 lamp fault level 2
- EF L1 earth fault level 1
- EF L2 earth fault level 2

Archive of ground fault detection TCR

Data selection by date or CCR or combination both. Select graph is windowing in main part of display:

- by days (graph of month)
- by hours (graph of day)







chapter:

2.3

SOFTWARE



METEOROLOGICAL EQUIPMENT

Application


- meteorological data for air traffic controller (for sending on board of the air-plane)
- automatic regulation of luminous intensity of airfield ground lighting equipment (data base the on measurement of runway visual range from the METAR/SPECI report)

→Connection

- serial lines RS-232 or TCP/IP
- working site Meteo is connected via the LAN network

➡Representation

- basic meteorological data are shown in the report "Airfield ground lighting" at the top part of the screen in meteorological ruler. This ruler contains a selection of the most important meteorological data.
- color shading gives to the air traffic controllers information about trend of the measured data, or about manually entered values
- remaining meteorological data (among others also QFE) are in the data windows Metreport, which can be opened from the top bar
- extended meteorological information is shown in the data window Meteo
- it is possible to switch representation of meteorological in requested runway directions
- tendency of the runway visual range is expressed by color shading of RVR, if the visual range is below 1500 m:



System provides the following information

- 1. direction and strength of wind with max and min values
- **2.** RVR if it is measured on RWY at corresponding number of measuring points
- 3. value BASE
- 4. VIS general visibility
- 5. QNH
- **6.** WX
- 7. temperature
- 8. dew point
- 9. bottom base of clouds

Meteo information (RVR) is used for automatic control of luminous intensity of individual sets.

Failure states

- in case of unavailability of meteorological information the whole panel changes its color to violet
- if this unavailability last for more than 5 minutes, all the data will disappear

RADIO-NAVIGATION EQUIPMENT (LLZ, GP, MM, OM, FFM, DME)

Description/Properties

- system AMS sends a request and waits for data
- monitoring is performed continuously, regardless of state of the system

Control of ILS

- control is effected by the air traffic controller with use of mouse (trackball) and cursor on display
- control is always selected in such a manner that only one working site may control ILS equipment, and control of ILS from other working sites is blocked



ILS 08



SOFTWARE

chapter:

2.3

CONTROL AND MONITORING LVP/LVTO

➡Application

- preparation of low visibility procedures (Prep LVP)
- operation LVP
- preparation of low visibility take-off (LVTO)
- operation LVTO

Description/Properties


- system AMS performs control of parameters determined by the system for individual phases and it offers to bodies of air traffic control a possibility to acknowledge or cancel the proposed mode of operation
- after declaration of LVP or LVTO the system checks operating ability of individual devices of aviation safety technics (hereinafter AST) designed for the given mode of operation and meteorological conditions
- in case of AST change it degrades in depending on character of failure operation gradually from higher level to lower level, or directly to CAT I
- in case meteorological conditions are changed with improving/deteriorating tendency it proposes to bodies of air traffic control change to the mode of operation, which corresponds to the current meteorological situation at the airport

System AMS displays in the text window under the meteorological ruler the following:

- selected mode of operation corresponding to failure of AST
- information, which is to be sent to the crew on board of the airplane

Control and monitoring of the following airport systems

- control of airfield ground lighting (for runways and taxiways - AGL), including system BRITE II and stop bars
- monitoring system for Low Visibility Procedures (LVP) and Low Visibility Take Off (LVTO)
- radionavigation equipment and systems (ILS, DME, NDB)
- radionavigation equipment En Route (VOR, DME)
- electric power systems (EPS)
- meteorological equipment (ME) AWOS protection zones
- central time
- AFTN
- data FPL Arrivals
- data FPL Departures • RWY in USE - SID



- monitoring and processing of basic information (weather, traffic restriction, emergency cases) designated for air traffic control
- ATIS information, including comparison of changes between the last 2 messages
- delivery of information (data) for central monitoringand control system

chapter:

2.3


SOFTWARE




ELECTRIC POWER SYSTEMS

➡Application

- control and representation of state of the airport electric power system
- interactive diagrams of the whole airport power system
- interactive representation of individual transformer sub-stations with control of individual compartments and distributor fields in low and high voltage sections
- it sends data about power system to the airport monitoring system CAT II and CAT III
- archiving of all events occurred in the system
- optical and acoustical indication of change of condition




TRAFOSTATION HTS



CONTROL AND MONITORING STOP BARS

Description/Properties

- stop bar ON
- stop bar OFF, following by centreline TWY







SOFTWARE

chapter:



MONITORING UPS

Description/Properties

The UPS backgrounds own status via values:

- start and end test of battery
- operation for battery (time)
- operation regime by-pass
- low battery
- supervision request


	Staveva Idiseni UPS IM 0655							
UPS	CAS V POCITACI CAS V UPS HLÁSENÍ A STAVOVÉ SLOVO					- 2		
	05;10,2002 04;04:0 05;10,2002 04;04:5 05;12,2002 03;55;4 05;12,2002 03;55;4 09;12,2002 03;55;4 09;12,2002 06;13;5 09;12,2002 06;13;5 09;17,2002 06;44:0	9 - 05.10.2002 0 6 - 05.12.2002 0 2 - 05.12.2002 0 5 - 09.12.2002 0 5 - 09.12.2002 0 0 - 09.12.2002 0	05:01:54 : konec 05:01:01 : start te 05:01:54 : konec 07:20:19 : napáje 07:20:41 : napáje	testu baterie stu baterie : testu baterie ni by pass n ni usmerno	: :000100111 0001000110 : :000100011 nimo toleran vace (si0 min	0010010 110010 0010010 ci : 000101 no toteram	ci : 0001010	10000
IM 065S	09.12.2002 06:44:2 09.12.2002 07:14:2 09.12.2002 07:14:2 09.12.2002 07:15:1 09.12.2002 07:15:1 09.12.2002 07:15:1 09.12.2002 07:14:2	9 . 09.12 2002 0 8 . 09.12 2002 0 1 . 09.12 2002 0 0 : porucha o 0 : porucha o 5 . 09.12 2002 0	07:51:21 : mapáje 08:21:21 : mapáje 08:21:43 : mapáje 6, 0502 : 6, : 00:51:18 : mapáje	ni usmerne ni by-pass r ni usmerne ni by pass r	vace (sif) min nimo toleran vace (sif) min nimo toleran	ne toleran ci : 000101 ne toleran ci : 000101	ci : 0001010 0180011010 ci : 0001019 0180011010	0000K
10-30 / 40-60 / 80-120 KVA	09.17.7007 07:44.5	4 -09.12.2002 C 7 -09.12.2002 C	08:51:42 : napáji 09:58:25 : napáji	ni usmerno ni hyaasse	vace (sil) mil	na toleran ci : 000101	0100011010	
10-30 / 40-60 / 80-120 kVA	09.12.2002 08:51:3 09.12.2002 08:52:0 *	2 - 09.12 2002 (1 - 09.12 2002 (09:58:25 : napáje 09:58:54 : napáje	ni by-pass r ni by-pass c	nimo toleran k : 00010001	ci : 000101	0100011010	
	09,12,2002 08:51:3 09,12,2002 08:52:9 * Záróz	2 - 09.12 2002 6 1 - 09.12 2002 6 Invertor	09:58:25 : napáje 09:58:54 : napáje Væ	ni hy-pass r ni by-pass c	nimo toleran k : 00010001 Baterle	ci : 000101 10010010	Výstup	ป
10-30 / 40-60 / 80-120 KVA	09.12 2002 08:51:3 09.12 2002 08:52:9 () 20062 UL1: 218V	2 - 09.12 2002 (1 - 09.12 2002 (1 - 09.12 2002 (Invertor UL1 2	09:58:25 : nopôje 09:58:54 : nopôje Van 219:V UL1	ni hy-pass r ni by-pass c up 226 V	nimo toleran & : 00010001 Baterle U :	ed : 000101 10010010 407.V	0100011010	لد ۵۸
	09.12.2002 08:51:3 09.12.2002 08:52:0 4 28:62 08:1 21:00 08:2 270V	2 × 09.12 2002 0 1 × 09.12 2002 0 Invertor UL1 2 UL2 2	09:58:25 : nopôje 09:58:54 : nopôje Vat 219.V UL1 226.V UL2	ni hyspans n ni byspans o 226 V 220 V	nimo toleran k: 00010001 Baterle U: L.	el : 000101 10010010 407 V -0.8 A	0100011010	ป
	09,12,2002 08:52:0 9,12,2002 08:52:0 4 28:65 08:1 : 218V 08:2 : 228V 08:3 : 218V	2 × 09.12 2002 0 1 × 09.12 2002 0 Invertor UL1 2 UL2 2	09:58:25 : nopôje 09:58:54 : nopôje Van 219:V UL1	ni hy-pass r ni by-pass c up 226 V	nimo toleran & : 00010001 Baterle U :	el : 000101 10010010 407 V -0.8 A 34 mm	0100011010	ป
	09-12 2002 08-512 0 09-12 2002 08-52 0 ≤1 Záróž UL3 = 218V UL2 = 220V UL3 = 218V UL3 = 218V UL3 = 218V	2 - 09.12 2002 6 1 - 09.12 2002 6 Invertor UL1 2 UL2 2 UL3 2	09:58:25 : nopôje 09:58:54 : nopôje Vat 219.V UL1 226.V UL2	ni hyspans n ni byspans o 226 V 220 V	nimo toleran k: 00010001 Baterle U: L.	el : 000101 10010010 407 V -0.8 A	0100011010	ป
	09,12,2002 08:52:0 9,12,2002 08:52:0 4 28:65 08:1 : 218V 08:2 : 228V 08:3 : 218V	2 - 09.12 2002 6 1 - 09.12 2002 6 Invertor UL1 2 UL2 2 UL3 2	09:58:25 : nopáje 09:58:54 : nopáje 219.V UL1 226.V UL2 219.V UL2	ni hyspans n ni byspans o 226 V 220 V	nimo toleran k: : 00010001 Baterle U: t: čas.	el : 000101 10010010 407 V -0.8 A 34 mm	0100011010	ป
	09-12 2002 08-512 0 09-12 2002 08-52 0 ≤1 Záróž UL3 = 218V UL2 = 220V UL3 = 218V UL3 = 218V UL3 = 218V	2 - 09.12 2002 6 1 - 09.12 2002 6 Invertor UL1 2 UL2 2 UL3 2	09:58:25 : nopáje 09:58:54 : nopáje 219.V UL1 226.V UL2 219.V UL2	ni hyspans n ni byspans o 226 V 220 V	nimo toleran k: : 00010001 Baterle U: t: čas.	el : 000101 10010010 407 V -0.8 A 34 mm	0100011010	2

MONITORING EMERGENCY POWER SUPPLY

Description/Properties

The PS backgrounds own status via values (for example):

- fuel in %
- operation power supply
- status of battery
- fault PS



SOFTWARE FOR ARCHIVES

Description/Properties

- all the data concerning operation of control workstations and information workstations, commands, handing over of control, requirements concerning constant current regulators and monitored signals are archived at central archive
- the data are archived for 1 year, after elapsing of one year they are automatically being deleted
- printing of archived data is possible on printer, which can be connected to any control or informative workstation

Program Data View Help	N						
Eat Prot Prode	W Export o	- 🌒	Refresh Fr	🐐 🔶	Next page	Last page	
Archiv select	Ovlada	ni					
Archev .	- The set	Čas	Událost	Cyladan/	_		
🕀 🔄 Ovládání	1		1 Occupier.				
The second second	965443	01.02.2001 05:07:54	Ovládání ILS 24				
	965444	01.02.2001 05:07:56 01.02 2001 05:08:13	Ovládár/ ILS 06	TS			
	965446	01.02.2001 05:08:13	Ovládání ILS 05 Ovládání ILS 05	uvoinéno			
	965447	01.02.2001 05:08:51	Oviadan/ ILS 05	uvoineno			
	965448	01.02.2001 05:08:51	Oviadar/ ILS 05	TEC			
	0965449	01.02.2001 05:08:54	Oviadari ILS 05	uvoinério			
	965450	01.02.2001 05:09:10	Cyladary ILS 05	TEC			
	0965451	01.02.2001 05:09:45	ILS 06 zapruto	The state of the s			
	965475	01.02.2001 05:10:39	Ovládán/ ILS 05	uvoinêna			
	0965501	01.02.2001 05:22:18	Ovládání ILS 24	TS			
	965502	01.02.2001 05:22:21	Ovládáry ILS 05	TS			
	965503	01.02.2001 05:22:23	Ovládání ILS 24	uvoinēna			
	965504	01.02.2001 05:22:26	Ovládári ILS 05	uvoinéno			
	965509	01.02.2001 05:22:51	Ovládání ILS 05	TEC			
	965510	01.02.2001 05:22:52	Ovládárý ILS 24	TEC			
	965511	01.02.2001 05:22:57	Cvládání ILS 05	uvoinēno			
	965512	01.02.2001 05:23:01	Ovládári ILS 05	TEC			
	0965513	01.02.2001 05:23:05 01.02.2001 18:37:42	ILS 06 vypnuto Ovládání 04-22	TEC			
Sun Mon Tue Wed Thu Fri Sat	967479	01.02.2001 18:37:42 01.02.2001 20:44:07	Ovládání 04-22 Ovládání 04-22	Uvoinēco			
	967971	02.02.2001 05:09:49	ILS 06 zapruto	CLACIT NET 2CI			
	967979	02.02.2001 05:09:09	ILS 06 zapruto				-
	По58041	02.02.2001 05:24:56	ILS 05 vypnuto				
	0969053	02.02.2001 07:00:31	Ovládáry 04-22	TEC			
	969276	02.02.2001 07:52:54	Ovladar/ D4-22	uvoinêno			
	969560	02.02.2001 13:00:38	Ovladari 04-22	TEC			
	970136	02.02.2001 15:07:21	Ovládání D4-22	uvoinério			-



chapter:







This page is intentionally left blank.

